

THE COPYRIGHT IN THESE DRAWINGS AND PLANS REMAINS VESTED IN SMART ENERGY SYSTEMS. THE DESIGNS AND PLANS MAY NOT BE USED WHOLLY OR IN PART WITHOUT THE WRITTEN PERMISSION OF SMART ENERGY SYSTEMS

SYSTEM SPECIFICATIONS


TOTAL MJ/HR RATING 125 MJ/HR

HOT & COLD PLUMBING EACH TANK

32mm CONNECTIONS AS STANDARD

SYSTEM PRODUCES AT 65°C 745 LITRES FIRST HOUR PEAK

ELECTRICAL CONNECTION AS INDICATED ON DRAWING



Model No. SGC-125

SMART ENERGY SYSTEMS

COMMERCIAL HOT WATER SYSTEMS

HEAD OFFICE
47 Johnston Street
SOUTHPORT QLD 4215

Ph: 1300 303 486
Fax: (07) 5571 0881
sales@smartenergysystems.com.au
www.smartenergysystems.com.au

DRAWING

Model No. SGC-125

FILE	DRAWN	SCALE
SGC-3-250	R.T.W.	N.T.S.