
THE COPYRIGHT IN THESE DRAWINGS AND PLANS REMAINS VESTED IN SMART ENERGY SYSTEMS. THE DESIGNS AND PLANS MAY NOT BE USED WHOLLY OR IN PART WITHOUT THE WRITTEN PERMISSION OF SMART ENERGY SYSTEMS



Model No. SGC-2-250X2


## SYSTEM SPECIFICATIONS

TOTAL mj/hr RATING 1000 mj/hr

HOT & COLD PLUMBING EACH TANK 32mm CONNECTIONS AS STANDARD

SYSTEM PRODUCES AT 65°c 4580 LITRES FIRST HOUR PEAK

ELECTRICAL CONECTION FOR WIRING PROVIDED WITH PLANT ELECTRICAL BOX INC ISOLATION SWITCH 240V 50hz NOMINAL 576 watts





COMMERCIAL HOT WATER SYSTEMS HEAD OFFICE

47 Johnston Street SOUTHPORT QLD 4215

SGC-3-250

Ph: 1300 303 486 Fax: (07) 5571 0881 salesØsmartenergysystems.com.au www.smartenergysystems.com.au

Model No. SGC-2-250X2

R.T.W.

N.T.S.

1980