


THE COPYRIGHT IN THESE DRAWINGS AND PLANS REMAINS VESTED IN SMART ENERGY SYSTEMS. THE DESIGNS AND PLANS MAY NOT BE USED WHOLLY OR IN PART WITHOUT THE WRITTEN PERMISSION OF SMART ENERGY SYSTEMS.



**SYSTEM SPECIFICATIONS**


TOTAL  $\text{m}^3/\text{hr}$  RATING 750  $\text{m}^3/\text{hr}$

HOT & COLD PLUMBING EACH TANK

50mm CONNECTIONS AS STANDARD

SYSTEM PRODUCES AT 65°C 3275 LITRES FIRST HOUR PEAK

ELECTRICAL CONNECTION AS INDICATED ON DRAWING



ELECTRICAL CONNECTION PROVIDED FOR WIRING WITH PLANT INCLUDING ISOLATION SWITCH 240V 50Hz NOMINAL 432W

SECONDARY HOT WATER RETURN (50mm BSP FEMALE)

MODEL NO: SGC-3-250

**SMART ENERGY SYSTEMS**

COMMERCIAL HOT WATER SYSTEMS

HEAD OFFICE  
47 Johnston Street  
SOUTHPORT QLD 4215

Ph: 1300 303 486  
Fax: (07) 5571 0881  
sales@smartenergysystems.com.au  
www.smartenergysystems.com.au

Model No. SGC-3-250